



**BUREAU OF ENVIRONMENTAL QUALITY**  
**Asbestos Abatement**  
**Final Clearance Inspection**

**Permit Number \***  
PAA230479

**Inspection Date \***  
08/28/2023

**Field Agent \***  
Victoria Monroe

**Job Site Name**

Salem United Methodist Church

**Address**

350 Manor Road

**City**

Wexford

**Zip code**

15090

**Contractor Name**

IVT Environmental Solutions, LLC

**I. Checklist**

- 2105.63.k A. Were critical barriers intact? Yes  No  N/A
- 2105.63.k B. Were negative air systems in operation? Yes  No  N/A
- 2105.63.k C. Were work areas properly wet cleaned? Yes  No  N/A
- 2105.63.j D. Air monitoring results at specified levels? Yes  No  N/A
- 2105.63.j E. Adequate number of samples collected? Yes  No  N/A
- 2105.63.j F. Air sampling results available? Yes  No  N/A

**II. Residual ACM ON:**

**If there was Residual ACM on any of the options below, choose "Yes" and provide more detail in the space provided:**

Yes  No

- 2105.63.k A. Floor
- 2105.63.k B. Horizontal Surfaces
- 2105.63.k C. Pipes
- 2105.63.k D. Ventilation Equipment
- 2105.63.k E. Ducts
- 2105.63.k F. Register
- 2105.63.k G. Lights

**Record Additional Details or Problems Below:**

Floor tile removed, mastic encapsulated removed from classrooms 3 and 5

### III. Final Air Clearance

2105.63.j Air Monitoring Firm: Enspec Environmental

- 2105.63.j A. Was hard copy on site? Yes  No
- 2105.63.j B. Were all samples <.01? Yes  No
- 2105.63.j C. Were sample procedures followed? Yes  No

#### Record Additional Details or Problems Below:

Is all work on the permit complete?

Yes  No

Based on visual inspection by Bureau personnel and data submitted by air monitoring firm. Final clearance is granted based on the provisions of Artical XXI, Rules and Regulations of Allegheny County?

Yes  No

#### Attached Photos/Documents (0)

Please attach any relevant items as needed:



**BUREAU OF ENVIRONMENTAL QUALITY**  
**Asbestos Abatement**  
**Pennsylvania ACT 194 Compliance Inspection**

**Permit Number**  
PAA230479

**Inspection Date**  
08/28/2023

**Field Agent**  
Victoria Monroe

**Job Site Name**  
Salem United Methodist Church

**Job Site Address**  
350 Manor Road

**Job Site City**  
Wexford

**Job Site Zip**  
15090

**Contractor Name**  
IVT Environmental Solutions, LLC

**Asbestos Supervisors and Workers Present at Project Site**

**Certification # \***  
036625

**Name \***  
Ivan Tkac

**Cert Expiration Date**  
07/24/2024

**Was Certificate Onsite? \***  
 Yes  No

**Certification # \***  
054402

**Name \***  
Douglas M Kozak Sr

**Cert Expiration Date**  
01/20/2024

**Was Certificate Onsite? \***  
 Yes  No